



GENERAL NOTES:

1. REU ENGINEERING WILL SPOT THE TEMPORARY SERVICE.
2. TEMPORARY SERVICE WILL NOT EXCEED 70 FT FROM REU POLE.
3. SERVICE DROP CLEARANCES SHALL BE AS FOLLOWS:
 - IN GENERAL - 12 FEET
 - DRIVEWAYS - 16.5 FEET
 - ROADS - 18 FEET
4. TEMPORARY SERVICE IS SUBJECT TO INSPECTION BY LOCAL CODES INSPECTOR.

PREPARED BY:	KDB
CHECKED BY:	JD
APPROVED BY:	KDB
ROCKWOOD ELECTRIC UTILITY 341 W. ROCKWOOD ST. ROCKWOOD, TN 37854	

**GUIDELINE FOR
OVERHEAD TEMPORARY
SERVICES**

SCALE: NONE	
DRAWING NUMBER	REV.
TS-01	0