



**NOTES:**

1. A MINIMUM OF 10 ft CLEARANCE SHALL BE REQUIRED BETWEEN BOTTOM OF "DRIP LOOP" AND FINAL GRADE.
2. CUSTOMER TO LEAVE 18"-24" OF SERVICE ENTRANCE CONDUCTORS EXTENDED FROM WEATHERHEAD AND IDENTIFIED PER NEC REQUIREMENTS.

PREPARED BY:	KDB
CHECKED BY:	JD
APPROVED BY:	KDB
ROCKWOOD ELECTRIC UTILITY 341 W. ROCKWOOD ST. ROCKWOOD, TN 37854	

**ASSEMBLY GUIDE  
RESIDENTIAL SERVICE MAST  
(150 VOLTS TO GROUND)**

<b>SCALE: NONE</b>	
<b>DRAWING NUMBER</b>	<b>REV.</b>
<b>OHS-001</b>	<b>0</b>