



## ELEVATION

### NOTES:

1. SECONDARY PEDESTAL TO BE FURNISHED BY REU AND INSTALLED BY CUSTOMER
2. PEDESTAL TO BE  $\pm 1/8$ " LEVEL
3. FINISHED GRADE MUST BE WITHIN  $\pm 1$ " OF THE TOP OF THE PEDESTAL.

PREPARED BY:	KDB	FIBERGLASS SECONDARY PEDESTAL – RESIDENTIAL INSTALLATION DETAIL	SCALE: NONE	
CHECKED BY:	JD		DRAWING NUMBER <b>UGS- 009</b>	REV.  <b>0</b>
APPROVED BY:	KDB			
ROCKWOOD ELECTRIC UTILITY 341 W. ROCKWOOD ST. ROCKWOOD, TN 37854				