



SERVICE ENTRANCE SIZE (AMPS)	CONDUIT SIZE	WIRE SIZE
100	2"	#2/0
200	2 1/2"	#4/0
400	3"	350 kcmil

NOTES:

1. CONDUIT BELOW GRADE SHALL BE SCH 40 PVC (SCH 80 UNDER ROADWAYS) UNLESS PRIOR APPROVAL OBTAINED FROM REU.
2. EXPOSED CONDUIT SHALL BE SCH 80 PVC OR EQUAL TO A POINT AT LEAST 8'-0" ABOVE FINISHED GRADE.
3. METER TO BE SPOTTED ON STRUCTURE BY REU.

PREPARED BY:	KDB	TYPICAL SINGLE-PHASE SECONDARY URD SERVICE	SCALE: NONE	
CHECKED BY:	JD		DRAWING NUMBER	REV.
APPROVED BY:	KDB		UGS-	0
ROCKWOOD ELECTRIC UTILITY 341 W. ROCKWOOD ST. ROCKWOOD, TN 37854			004	