



NOTES:

1. CONDUIT BELOW GRADE SHALL BE SCH 40 PVC UNLESS PRIOR APPROVAL OBTAINED FROM REU.
2. EXPOSED CONDUIT SHALL BE SCH 80 PVC OR EQUAL TO A POINT AT LEAST 8'-0" ABOVE FINISHED GRADE.
3. METER TO BE SPOTTED ON STRUCTURE BY REU.
4. CUSTOMER TO INSTALL PULL STRING IN ALL CONDUIT.

PREPARED BY:	KDB	TYPICAL SINGLE-PHASE SECONDARY URD SERVICE	SCALE: NONE	
CHECKED BY:	JD		DRAWING NUMBER	REV.
APPROVED BY:	KDB		UGS-	1
ROCKWOOD ELECTRIC UTILITY 341 W. ROCKWOOD ST. ROCKWOOD, TN 37854			004	